

-10 -25 73 kW@1500 rpm 72 kW@1800 rpm **EU 2002/88/EC**

Specifications				
Thermodynamic cycle		Diesel 4 stroke		
Air intake		TC		
Arrangement		4, in line		
Bore x Stroke	mm	104 x 132		
Total displacement		4.5		
Valves per cylinder		2		
Injection system		direct		
Speed governor		mechanical		
Cooling system		liquid (water + 50% Paraflu11)		
Flywheel housing/flywheel	type	SAE3 / 11" 1/2		
Flywheel rotation		CCW		
Lube oil specifications		ACEA E3-E5		
Lube oil consumption		<0.1% of fuel consumption		
Fuel specifications		EN 590		
Oil and filters intervals for replacement	hours	600		
Fuel consumption at:	rpm	1500	1800	
	100% load I/h (g/kWh)	17.1 (214.2)	17.3 (215.5)	
	80% load I/h (g/kWh)	12.7 (212.1)	13.0 (216.0)	
	50% load I/h (g/kWh)	8.6 (214.1)	9.0 (225.9)	
Coolant capacity: engine only	1	~8.5		
engine+radiator	1	~18.5		
ATB (without canopy)	°C	55		
Lube oil total system capacity including pipes, filters etc.		~12.8		
Electrical system		12Vcc		
Starting batteries: recommended capacity	Ah	1×100		
Discharge current (EN 50342)	А	650		

Performances

Cold starting: without air preheating

with air preheating

Ratings ¹			1500 rpm		1800 rpm	
		PRIME	STAND-BY	PRIME	STAND-BY	
Rated Output ²	kWm	66	73	65	72	

- 1) Ratings in accordance with ISO 8528. For duty at temperature over 40°C and/or altitude over 1000 meters must be considered a power derating factor. Contact the FPT sales organization.
- 2) Net power at flywheel available after 50 hours running with a $\pm 3\%$ tolerance.

PRIME POWER: The prime power is the maximum power available with varying loads for an unlimited number of hours. The average power output during a 24h period of operation must not exceed 80% of the declared prime power between the prescribed maintenance intervals and at standard environmental conditions. A 10% overload is permissible for 1 hour every 12 hours of operation.

STAND-BY POWER: The stand-by power is the maximum power available for a period of 500 hours/year with a mean load factor of 90% of the declared stand-by power. No kind of overloads is permissible for this use.

CONTINUOUS POWER: Contact the FPT sales organization.

Standard configuration

FPT engine N45 SM2A equipped with:

- Mounted radiator
- Mounted belt driven pusher fan
- Fan guard
- Mounted air filter with replaceable cartridges
- Fuel filter
- Primary fuel filter/water separator
- Replaceable oil filter
- Front engine mounting brackets
- Flywheel housing SAE3 and flywheel 11"1/2
- Re-directable exhaust gas elbow
- Recirculed oil breather system
- Oil dipstick
- HWT and LOP sensors
- 12 Vdc electrical system
- User's handbook

THE ENGINE IS SUPPLIED WITHOUT LIQUIDS

Optional equipment:

On request the engine can be supplied with:

- Oil drain pump
- Oil drain valve
- 120/230 Volt water jacket heater
- WT and OP sensors for gauges
- Low water level sensor
- Turbo and exhaust gas guards
- Exhaust gas flexible joint
- 24 Volt electrical system

Overall dimensions:

